Rhododendron Water Association Consumer Confidence Report for the year 2010

Is my water safe?

Last year, as in recent years past, your tap water met all U.S. Environmental Protection Agency (EPA) and state drinking water health standards. Local Water vigilantly safeguards its water supplies and once again we are proud to report that our system has not violated a maximum contaminant level or any other water quality standard. Exceptions, the CCR 2009 report was not received by the Drinking water program on time. A Coliform sample was not received by the Drinking water program due to mislabeling by the laboratory company.

Do I need to take special precautions?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Water Drinking Hotline (800-426-4791).

Where does my water come from?

The Rhododendron Water Association obtains it source of water from Henry Creek with a diversion structure located in Mount Hood National Forest in the foot hills of Zig Zag Mountain. The water is treated using Multimedia (sand) filters and Rosedale brand cartridge filters to remove turbidity, Cryptosporidium and Giardia. Sodium Hypochlorite (NaOCl) is added to provide disinfection residual throughout the distribution system.

Source water assessment and its availability

The State of Oregon Department of Environmental Quality (DEQ) has completed a Source water assessment and the summary can be viewed at the following web site: http://www.deq.state.or.us/wq/dwp/docs/swasummary/pws00702.pdf

Why are there contaminants in my drinking water?

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's (EPA) Safe Drinking Water Hotline (800-426-4791). The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. These include: A) Microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife. B) Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban stormwater runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming. C) Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses. D) Organic Chemical Contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems. E) Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

How can I get involved?

Attend the Annual General Membership Meeting. It is held every year on a Saturday in May, the meeting notice is enclosed. You can also help us keep costs down by reporting leaks and other maintenance issues to our main office at 503-622-5560 or our Water Master, David Jacob; Cell 503-310-9262

Other Information

Planned System Upgrades: We are in a multi year meter installation program. You will receive notification and details when the work is ready to begin and how the construction work may affect access to your homes or cabins.

Water Quality Data Table

The table below lists all of the drinking water contaminants that we detected during the calendar year of this report. The presence of contaminants in the water does not necessarily indicate that the water poses a health risk. Unless otherwise noted, the data presented in this table is from testing done in the calendar year of the report. The EPA or the State requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently.

Contaminants (units)	MCLG	MCL	Your	Range		Sample	Violation	Typical Source
			water	High	Low	Date		
Disinfectants & Disinfection By-Products								
Sodium Hypo-Chlorite (ppm)	4.0	4.0	0.6 Ave	2.5	0.21	Daily	No	Water additive used to control microbes
Total Halo Acetic Acids		60	12.3	12.3	12.3	9/27/10	No	Now Sampled Annually
Total Trihalomethanes		80	9.4	9.4	9.4	9/27/10	No	

Contaminants (units)	MCLG	MCL	Your	Range		Sample	Violation	Typical Source	
			water	High	Low	Date			
Microbiological Contaminants									
Turbidity	n/a	<1	.050	<1	.029	Daily	No	Soil Runoff	
			average						
Total Coliform	0	0	0			Monthly	No	Naturally present in the environment	

Contaminants (units)	MCLG	MCL	Your water	Number of samples above action level	Sample Date	Violation	Typical Source		
Inorganic Contaminants									
Copper (ppm)	1.3	1.3	0.250	0	09/10/08	No	Erosion of natural deposits; Leaching from wood preservatives; Corrosion of household plumbing systems.		
Lead (ppb)	0	15	5.3	0	09/10/08	No	Erosion of natural deposits; Leaching from wood preservatives; Corrosion of household plumbing systems.		

Units Description:

ND: Not detected NR: Not reported NA: Not applicable ppm: parts per million, or milligrams per liter (mg/L)

ppb: parts per billion, or micrograms per liter (µg/L)

MNR: Monitoring not required, but recommended.

NTU: Nephelometric Turbidity Units. Turbidity is a measure of the cloudiness of the water. We monitor it because it is a good indicator of the effectiveness of our filtration system. # of monthly positive samples: Number of samples taken monthly that were found to be positive.

Important Drinking Water Definitions:

MCLG: Maximum Contaminant Level Goal. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLG's allow for a margin of safety

MCL: Maximum Contaminant Level. The highest level of a contaminant that is allowed in drinking water. MCL's are set as close to the MCLG's as feasible using the best available treatment technology. TT: Treatment Technique. A required process intended to reduce the level of a contaminant in drinking water.

AL: Action Level. The concentration of a contaminant, which, if exceeded, triggers treatment or other requirements that a water system must follow.

MRDLG: Maximum residual disinfection level goal. The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLG's do not reflect the benefits of the use of disinfectants to control microbial contaminants.

MRDL: Maximum residual disinfectant level. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Spanish (Español)

Este informe contiene informacion muy importante sobre la calidad de su agua beber. Traduscalo o hable con alguien que lo entienda bien.

Ce rapport contient des informations importantes sur votre eau potable. Traduisez-le ou parlez en avec quequ'un qui le comprend bien.